

ADDENDUM #6:

Butler County Jail Remodel

705 Hanover St.
Hamilton, Ohio 45011

Prepared by:

LWC Incorporated
434 E. First Street
Dayton, Ohio 45402
(937 223-6500)



January 24, 2024

The contents of this Addendum shall become a part of the Contract Documents as if originally incorporated therein and as stated in Section 007100 – Contracting Definitions.

Item No. 1: Substitution Requests

1. Addendum 5, Alternative Isolation Room Ceiling: In addition to the manufacturer's listed in Addendum 5 for the Alternative Isolation Room Ceiling, subject to compliance with requirements, products from Claborn Manufacturing, Tanner, AL, claborn.com, may be incorporated into the project.

Item No. 2: Questions and Answers

1. **Question:** Is the contractor responsible for pulling, terminating and testing the data/communications lines? Or are we providing pathways only? If we are providing the cabling, what comm room do they get pulled back to? Do you have a communication contractor who services/installed your current data cabling? **Answer:** The General Contractor and their subcontractors are responsible for both pathways and pulling, terminating and testing the data/communications lines. The Butler County Jail systems are serviced by Unique Security Inc., 844 Lagoon Commercial Blvd., Montgomery, AL 36117, (334) 239-8343. See Addendum 4 for location of terminal room.
2. **Question:** Is the contractor responsible for adding security cameras to the renovated space as the documents show only approximate locations? Or are we providing pathways only? If we are providing/adding cameras, where does the camera cabling get pulled? Does the system have

spare capacity to add more cameras? Do you have a spec on type of camera? Do you have an A/V contractor who services/installed your current CCTV system? **Answer:** The General Contractor and their subcontractors are responsible for providing cameras in the locations shown and connected to the existing system for a fully operational system. The Butler County Jail systems are serviced by Unique Security Inc., 844 Lagoon Commercial Blvd., Montgomery, AL 36117, (334) 239-8343. See Addendum 4 for location of terminal room. Unique Security is to match existing cameras.

3. **Question:** The contractor is to provide and install a new receptacle control panel. We are to integrate that into the existing jails security interface. What system do we need to interface to? Is there a contractor the jail uses who does that programming? **Answer:** The Butler County Jail systems are serviced by Unique Security Inc., 844 Lagoon Commercial Blvd., Montgomery, AL 36117, (334) 239-8343. Unique Security is to integrate new work to the existing system.
4. **Question:** Is the existing roof metal decking with insulation? **Answer:** The existing roof system consists of metal deck on steel joists and tapered insulation with a built-up membrane.
5. **Question:** What type of roofing and is it under warranty? If so, who is the warranty with? **Answer:** The roof membrane is a Tremco 3-ply modified bitumen roof that is under an extended warranty.

End of Addendum 6